



Parcel 54-A-3A is approximately 3,000 ft from sanitary sewer and 4,500 from water service. It would appear that sewer could be provided to the site without the need for a pump station. It would be up to the developer to obtain all easements and pay for the cost of the water and sewer improvements.